



# LICKING TOWNSHIP

## *Fire Company*

### Ohio Specific Provisions related to the 2017 Ohio Fire Code

These provisions state the requirements of the Licking Township Fire Company and its Fire Code Officials that are issued under the authority of the 2017 Ohio Fire Code ("OFC"), including but not limited to Section 104 General Authority and Responsibilities as contained in the Ohio Administrative Code Section 1301:7-7-01.

#### A. Applications and Permits

- a. Per the OFC, **Section 104.2 Applications and Permits**, the fire code official is authorized to receive applications, review construction documents and issue permits for construction regulated by this code, issue permits for operations regulated by this code, inspect the premises for which such permits have been issued and enforce compliance with the provisions of this code.
- b. Per the OFC, **Section 104.2.1.1** receive and review fire protection system and associated fire safety feature related construction documents when notice is provided to the building code official in accordance with Section 106.1.2 of the building code as listed in rule 1301:7-7-80 of the Administrative Code.

All plans for proposed new, modified, or enlarged structures or developments in the Licking Township Fire Company coverage area shall be submitted to the Fire Code Official for review of fire hydrants, fire alarms, fire apparatus access, fire suppression systems, underground fire lines, fire department connections, etc. prior to any construction.

#### B. Types of Permits

The following is the Permit/Fee Schedule adopted by the Licking Township Board of Trustees as set forth in the Ohio Fire Code **Sections 105.1.1, and 105.1.1.2**, Ohio Administrative Code 1301:7-7-01. All fire protection systems and building plans shall be submitted to the Licking Township Fire Company through the respective Building Code Department (Licking County) for review and comment by both entities prior to initiation of any construction. All permits and fees shall be paid in full prior to any demolition or construction. This permit and fee schedule is in addition to those required by the respective Building Code Department.

✓ The Fire Code Official may waive the fee when the permit is obtained by a non-profit organization or is for a non-profit function.

✓ As-built plans are required to be submitted by electronic media in PDF format upon completion of construction.

✓ ALL contractors found working without an approved permit shall be charged twice the permit fee.

All permit fees shall be made payable by check to (non-refundable):

**Licking Township Fire Company**

Payment may be mailed to: PO Box 228 Jacksontown, Ohio 43030

Please reference the business name and address on the check.

- a. 105.1.1 Permits required. A property owner or owner's authorized agent who intends to conduct and operation or business or install or modify systems and equipment that are regulated by this code, or to cause any such work to be performed, shall first make application to the fire code official and obtain the required permit.
- b. The Fire Code Official may issue Mandatory permits which include but are not limited to, Fire Protection System permits, Temporary Membrane Structure; Tents/Canopy permit and Exhibition of Fireworks permits. The Fire Code Official may also issue Discretionary Permits and Notification of Hazardous Activities permits



# LICKING TOWNSHIP

## *Fire Company*

### Inspection Fee Schedule

#### Part I: Plan Review- \$250.00

Megaproject Plan

Commercial Plan

Subdivision/Apartment Complex

#### Part II: Construction Permits - Fire Protection Systems- \$200.00

Automatic Sprinkler Systems (New Build)	Sprinkler System addition/alteration
Independent Standpipe System	Underground Fire Line
Automatic Extinguishing Systems (CO2, Clean Agent, Dry Chemical)	Kitchen Hood System
Automatic/Manual Fire Alarm Systems	Alarm System addition/alteration
Emergency Responder Radio System	Battery systems
Compressed Gases	Cryogenic fluids
Flammable/Combustible Liquids	Hazardous Materials
Smoke Control/Exhaust Systems	Tent/Membrane Inspection
Construction Trailers	

#### Part III: Operational (Annual) Permits

Fireworks/Pyrotechnics	\$500 Base Permit Fee per show
Flammable and Combustible Liquids	\$250 per building in excess of allowable limits
Hazardous Materials	\$250 per building in excess of table 105.6.21
Food Truck/Trailer	\$200 per
Tent	\$150 per
Above Ground Flammable Liquid Storage Tank	\$200 per
Special Event Permits- Includes Above Permits	
Special Event Permit- Minor-Less than 1,000	\$150 Base Permit Fee per show
Special Event Permit- Minor-Less than 1,000 (Pyrotechnics/Fireworks)	\$3,000 Base Permit Fee per show
Special Event Permit Small-1,000 to 5,000	\$3,000 Base Permit Fee per show
Special Event Permit- Medium-Less than 10,000	\$5,000 Base Permit Fee per show
Special Event Permit- Large- Greater than 10,000	\$7,500 Base Permit Fee per show

#### Administration Fee

#### Part IV: Annual Inspection and permit fees

Above Ground Flammable Liquid Storage Tank- \$200

#### Miscellaneous Fees

Fire Watch/Special Duty

\$35.00 per hour per inspector required.

\$35.00 per hour per firefighter required.

Unit/Vehicle Fee

Ambulance: \$195.00 per hour

Fire Engine: \$225.00 per hour

Utility Vehicle/ Grass Truck: \$80.00 per hour

UST Any required permit or inspection for UST installation, alteration or removal will be directed to the State of Ohio Fire Marshal's Office at (614) 752-8200.

Alternative Energy generation

Permit fee \$400 and the Fire Code Official may elect to have the system and energy storage independently evaluated. The cost of the independent inspector shall be at the cost of the installer.



# LICKING TOWNSHIP

## *Fire Company*

<b>Licking Township Special Event Inspection Fee Schedule:</b>		
<b>MINOR EVENT</b> No Pyrotechnics/Fireworks	Less Than 1,000 Attendees	<b>\$150.00 per event</b> (Includes 1 hour inspection)
<b>MINOR EVENT</b> Pyrotechnics/Fireworks	Less Than 1,000 Attendees	<b>\$3,000 per event</b> (Includes Special Permit Fee) <ul style="list-style-type: none"> <li>• \$35/hour per Inspector required</li> <li>• 35/ hour per firefighter required</li> <li>• Unit/ Apparatus Fee</li> </ul>
<b>SMALL EVENT</b>	Less Than 5,000 Attendees	<b>\$3,000 per event</b> (Includes Special Permit Fee) <ul style="list-style-type: none"> <li>• \$35/ hour per Inspector required</li> <li>• \$35/hour per firefighter required</li> <li>• Unit/ Apparatus Fee</li> </ul>
<b>MEDIUM EVENT</b>	Less Than 10,000 Attendees	<b>\$5,000 per event</b> (Includes Special Permit Fee) <ul style="list-style-type: none"> <li>• \$35/hour per Inspector required</li> <li>• \$35/hour per firefighter required</li> <li>• Unit/ Apparatus Fee</li> </ul>
<b>LARGE EVENT</b>	More Than 10,000 Attendees	<b>\$20,000 per event</b> (Includes Special Permit Fee) (credit of \$12,500 towards payroll) <ul style="list-style-type: none"> <li>• \$35/hour per Inspector required</li> <li>• \$35/hour per firefighter required</li> <li>• Unit/ Apparatus Fee</li> </ul>
<b>Licking Township Food Truck Inspection Fee Schedule:</b>		
<b>Non-Special Event Food Trucks annually (**)</b>		<b>\$200.00</b>
(**) Non-Special Event Food Trucks MUST be inspected at Licking Township Fire Company prior to operation within Licking Township. If found to be operating without proper permit the property owner will be responsible for permit fees.		

- All Inspection Fees are due at the time of 1st inspection
- Special Event Permits/Food Truck Inspection Decal will **not** be issued until payment rcvd in full
- Payment may be made by check (only) and is non-refundable
- Make checks payable to: Licking Township Fire Company
- Medium & Large Event Inspection Fee includes food truck inspection fee
- Inspection Fees are waived for schools, churches, & government entities



# LICKING TOWNSHIP

## *Fire Company*

### **A. Witnessing of Acceptance Testing / Retest**

- a. The responsible person shall schedule the attendance and witnessing of an acceptance test or retest with the Fire Code Official at least forty-eight (48) hours prior to the desired test date and time.
- b. Prior to scheduling an inspection, test or retest, the responsible person shall submit to the Fire Code Official, a Statement of Compliance (a.901.5.1) of the 2017 Ohio Fire Code. All fees shall be paid in full prior to scheduling the inspection, test, or retest.
- c. Inspections will begin promptly at the scheduled time. Should the inspection not be ready to take place at the scheduled time, the inspection may be deemed incomplete, a re-inspection will need to be scheduled and a fee may be assessed by the Fire Code Official. The Licking Township Fire Company will not construct "punch lists" for projects.

### **B. Final Inspection**

The responsible person shall schedule a final inspection with the Fire Code Official at least forty-eight (48) hours prior to the desired date and time for the inspection. All fees shall be paid in full prior to scheduling the final inspection.

### **C. Construction Documents**

- a. Submittals shall be per the OFC Sections 105.4.1 Submittals and 105.4.2 Information on Construction Documents, with one (1) copy of each submittal, in electronic media via pdf or flash drive, being tendered to the Fire Code Official.
- b. Electronic Media – One (1) base drawing of each sheet, at a standard engineering scale (1:10, 1:20, 1:30, 1:40, 1:50, 1:60) on a USB drive. Drawings shall be of sufficient clarity to indicate the location, nature and extent of the work proposed and show in detail that the work will conform to the provisions of the OFC, relevant laws, and these specific provisions.
- c. Submittals shall be per the OFC Section 105.4.1 Submittals and permits.
- d. Plans submitted shall include the following information at a minimum:
  1. Building layout on property showing parking lot entrances, fire hydrant locations, building entrances, FDC location, PIV locations, emergency generator location, and vehicle hazards indicating North.
  2. Complete floor plan for each level with exits noted, standpipe locations, fire doors, special hazards and loading docks.
  3. Sprinkler zones for all floors
  4. Firewall locations for each floor.
  5. Locations of all utility shut offs.
  6. Hazardous Materials – including quantity's, storage locations and SDS Information
  7. Knox Box key locations(s)
  8. Details for high-pile/combustible storage. This shall include NFPA 13 required owner's certificate or an equivalent level of details.
  9. The Architect or General Contractor shall provide an overview layout of the building showing the locations of the main electrical rooms, fire pump room, sprinkler riser area / room, main fire alarm panel, remove fire alarm panel and Knox Box locations on a flash drive or pdf.

### **D. Premises Identification**

- a. In the OFC Section 505.1 Address identification. New and existing buildings shall be provided with approved address identification. The address identification shall be legible and placed in a position that is visible from the street or road fronting the property. Where required by the fire code official, address identification shall be provided in additional approved locations to facilitate emergency response. Where access is by means of a private road and the building cannot be viewed from the public way, a monument, pole or other sign or means shall be used to identify the structure. Address identification shall be maintained. The West Licking Joint Fire District specifications call for a minimum size in height of 6" with a minimum stroke width of 1" letters/numbers of contrasting color. The fire department only requires the actual digits of the address not the street name, unless specified specifically by the fire code official.

### **E. Multi- Tenant Commercial or Industrial Occupancies**

- a. a. In relation to the OFC Section 403.11.1.5 Tenant identification shall be provided for secondary exits from occupied tenant spaces that lead to an exit corridor or directly to the exterior of the building. Tenant identification shall be posted on the exterior side of the exit or exit access door. Letters and numbers shall be posted on the corridor side of the door, be plainly legible and shall contrast with their background. The letters /numbers shall be 6" in height and have a minimum stroke width of 1". b. Per the OFC Section 509.1.1 Utility identification. Where required by the fire code official, gas shutoff valves, electric meters, service switches and other utility equipment shall be clearly and legibly marked to identify the unit or space



# LICKING TOWNSHIP

## *Fire Company*

that it serves. Identification shall be made in an approved manner, readily visible and shall be maintained. All doorways both inside and outside of a structure that access any utilities or suppression system i.e.: sprinkler riser, fire pump etc., shall also be identified with letters/numbers 6" in height and have a minimum stroke width of 1". This rule shall include roof access identification. All exterior doors shall be painted fire protection red leading into the fire pump room sprinkler riser areas/ room and main fire alarm panel.

- c. Protective Bollards shall be required anywhere specified by the fire code official for protection of utilities, building safety systems or as required by the fire code official. Bollards shall be installed per OFC section 312.2.

### **F. Hazard Communication**

- a. In relation to the OFC Section 407 Hazard Communication; Material Safety Data Sheets shall be provided as a paper copy and shall be located to the right side of the main front door of the structure and no more than three (3) feet inside of the door. The top of the holder of the Material Safety Data Sheets shall be a maximum of 75" above the finished floor. The location shall be approved by the Fire Code Official and is subject to change at the Fire Code Officials discretion.

### **G. Key (Knox Box) Boxes**

- a. Per the OFC Section 506.1 Where required. Where access to or within a structure or an area is restricted because of secured openings or where immediate access for life-saving or firefighting purposes, the Fire Code Official is authorized to require a key box to be installed in an approved location. The key box shall be of an approved type listed in accordance with UL 1037 as listed in rule 1301:7-7-80 of the Administrative Code and shall contain keys to gain necessary access as required by the fire code official.
- b. In relation to the OFC Section 506.1.1 Locks. An approved lock shall be installed on gates or similar barriers where required by the fire code official.
- c. The style of Knox Box shall be approved prior to purchase and installation to confirm that it meets the specifications of the West Licking Joint Fire District. Placement of the Knox Box shall also be confirmed with the Fire Code Official prior to installation. The height of the Knox box shall be between 42 and 60 inches above the finished grade and when possible, situated to right side of entry
- d. A card containing the emergency contact people and phone numbers shall be placed inside the box. The Licking Township Fire Company requires three (3) master keys for each Knox box and each key shall be attached to a small "D" ring.

### **H. Emergency Responder Radio Coverage**

- a. Per the OFC Section 510.1 Emergency responder radio coverage in new buildings. All new buildings shall have approved radio coverage for emergency responders within the building based upon the existing coverage levels of the public safety communication systems of the jurisdiction at the exterior of the building. This paragraph shall not require improvement of the existing public safety communication systems.
- b. Per the OFC Section 510.3 Permit required. A construction permit for the installation of or modification to emergency responder radio coverage systems and related equipment is required as specified in paragraph (E)(7)(e)(105.7.5) of rule 1301:7- 7-01 of the Administrative Code. Maintenance performed in accordance with this code is not considered a modification and does not require a permit.
- c. Per the OFC Section 510.4.1 Radio signal strength. The building shall be considered to have acceptable emergency responder radio coverage when signal strength measurements in 95 per cent of all areas on each floor of the building meet the signal strength requirements in paragraphs (J)(4)(a)(i)(510.4.1.1) and (J)(4)(a)(ii)(510.4.1.2) of this rule.
- d. Per the OFC Section 510.4.1.1 Minimum signal strength into the building. A minimum signal strength of - 95 dBm shall be receivable within the building.
- e. Per the OFC Section 510.4.1.2 Minimum signal strength out of the building. A minimum signal strength of -95 dBm shall be received by the agency's radio system when transmitted from within the building.
- f. Per the OFC Section 510.4.2.2 Technical criteria. The fire code official shall maintain a document providing specific technical information and requirements for the emergency responder radio coverage system. This document shall contain, but not be limited to, the various frequencies required, the location of radio sites, effective radiated power of radio sites, and other supporting technical information.
- g. Per the OFC Section 510.6.1 Testing and proof of compliance. The emergency responder radio coverage system shall be inspected and tested annually or where structural changes occur including additions or remodels that could materially change the original field performance tests. Testing shall meet this OFC section. Third party certification of compliance with this code requirement will be required prior to final occupancy approval by the Licking Township Fire Company and/or its agents. Pre and post ERRS test reports shall be emailed to the Fire Code Official.

### **I. Fire Apparatus Access**



# LICKING TOWNSHIP

## *Fire Company*

**Roads Definition: FAAR** – A road that provides fire apparatus access from a fire station to a facility, building or portion thereof. This is a general term inclusive of all other terms such as fire lane, public street, private street, parking lot lane, and access roadway.

- a. In relation to the OFC Section 501.3 Construction Documents. Construction documents for proposed fire apparatus access, location of fire lanes, security gates across fire apparatus access and construction documents and hydraulic calculations for fire hydrant systems shall be submitted to the fire department for review and approval prior to construction. Prior to any above ground construction, a professional engineer shall complete and submit to the Fire Code Official for approval.
- b. In relation to the OFC Section 503.1.1 Buildings and facilities. Approved fire apparatus access roads shall be provided for every facility, building or portion of a building hereafter constructed or moved into or within the jurisdiction which are not readily accessible from a public and/or private street. The fire apparatus access road shall comply with the requirements of this paragraph and shall extend to within 150' (45,720 mm) of all portions of the facility and all portions of the exterior walls of the first story of the building as measured by an approved route around the exterior of the building or facility. The fire apparatus access road shall provide access to a minimum of three sides of the building or facility \* The Fire Code Official is authorized to increase the dimension of 150' (45,720 mm) and every FAAR shall be maintained throughout construction
- c. In relation to the OFC Section 503.1.2 Additional Access. The fire code official is authorized to require more than one fire apparatus access road based on the potential for impairment of a single road by vehicle congestion, condition of the terrain, climatic conditions or other factors that could limit access. The West Licking Joint Fire District requires 2 permanent means of access for all developments.
- d. Per the OFC Section 503.2.1 Dimensions. Fire apparatus access roads shall have an unobstructed width of not less than 20' (6096 mm), exclusive of shoulders, except for approved security gates in accordance with paragraph (C)(6) (503.6) of this rule, and an unobstructed vertical clearance of not less than 13' 6" (4115 mm).
- e. The Fire Code Official shall have the authority to require an increase in the minimum access width where they are inadequate for fire and rescue operations.
  1. Fire apparatus access roads shall be designed and maintained to support the imposed loads of fire apparatus weighing at least 85,000 pounds and shall be surfaced so as to provide all-weather driving capabilities. The Fire District doesn't allow grass pavers. The emergency access drive/road shall be paved with asphalt or concrete.
  2. The required turning radius of a fire apparatus road shall be determined by the Fire Code Official. Cul-de-sacs shall have a minimum of 96' of unobstructed paved drivable surface, posted with signs that states "No Parking".
  3. All streets that are 28' or less in width shall have signs posted on the fire hydrant side of the street stating, "NO PARKING".
  4. Dead-end fire apparatus access roads in excess of 150' in length shall be provided with an approved area for turning around fire apparatus.
- f. Per the OFC Section (3) 503.3 Marking. Where required by the fire code official, approved signs or other approved notices or markings that include the words "NO PARKING-FIRE LANE" shall be provided for fire apparatus access roads to identify such roads or prohibit the obstruction thereof. The means by which fire lanes are designated shall be maintained in a clean and legible condition at all times and be replaced or repaired when necessary to provide adequate visibility.
- g. Vehicle access for firefighting shall be provided to all construction demolition sites. Vehicle access shall be provided to within 100' of temporary or permanent fire department connections. Vehicle access shall be provided by either temporary or permanent roads, capable of supporting the imposed load of fire apparatus weighing at least 85,000 pounds under all weather conditions.
- h. All residential subdivisions or complexes with 30 or more units require 2 accesses minimum. This includes single family condominiums or multi-family (apartments).

### **J. Fire Hydrants**

The Licking Township Fire Company shall have final approval on all locations of fire hydrants prior to any construction.

- a. Per the OFC Section 507.1 Required water supply. An approved water-supply capable of supplying the required fire flow for fire protection shall be provided to premises upon which facilities, buildings or portions of buildings are hereafter constructed or moved into or within the jurisdiction.
- b. The maximum distance between fire hydrants shall be 300' in commercial districts and 500' in residential areas.
- c. Fire hydrants shall be provided no less than 20' nor more than 50' of all intersecting streets.



# LICKING TOWNSHIP

## *Fire Company*

- d. One (1) fire hydrant shall be provided within one-hundred and fifty 150' of the terminus of a public or private dead-end street, stub street, common access drive, or cul-de-sac.
- e. Fire hydrants shall not require the opening of a valve for the fire hydrants to provide the required fire flows needed.
- f. Hydrant flow testing, as recommended per NFPA 291, shall be conducted, and documented to ensure that the minimum fire flow is available. These tests shall be conducted at the expense of the owner.
- g. The Licking Township Fire Company shall be notified for the opportunity to witness these tests
- h. Fire hydrant and water line plans shall be submitted electronically to the West Licking Joint Fire District.
- i. The minimum water line size for a fire hydrant shall be 6". If the water line is a dead-end line and exceeds 600' in length or has two (2) or more hydrants on the line, an 8" pipe size is required.
- j. The minimum branch size for a fire hydrant shall be six 6".
- k. Fire hydrants shall have: - One (1) 5" Male connection - Two (2) 2.5" hose connections - Meet the NFPA National Standard fire hose threads.
- l. Additional fire hydrant requirements: - Set the depth so that the breakaway flange is within 6" above the finish grade. - The steamer connection shall be facing the road. - Check the hydrant to ensure that there is no leakage at breakaway flange and that the water freely drains through the weep hole when shut off.
- m. Fire hydrants shall be in-service, and a letter received from the local water department with a certificate of completion from the installing contractor prior to construction above grade. All hydrants shall remain functional and in service after this step. m.
- n. Each project shall provide 1 spare "screw on" type Storz fitting for every five (5) fire hydrants installed on the water line to be used at the discretion of the Fire District. They shall be delivered to the Fire District prior to final acceptance of the project.
- o. All fire hydrants on a private system shall be painted fire protection red and have the bonnet of the hydrant painted blue. A private system is defined as ANY hydrant not maintained or is the responsibility of the Water Dept.

### **K. Fire Suppression Systems**

- a. A copy of the sprinkler plans APPROVED BY THE WEST LICKING JOINT FIRE DISTRICT shall remain on site after building occupancy.
- b. Post Indicating Valve - Sprinkler systems other than limited area systems, as defined in The Ohio Building Code, shall have a post indicating valve installed. The post indicating valve shall be monitored at a constantly attended location and/or kept locked. Post indicator valve locations shall be approved by the Licking Township Fire Company. All control valves shall be provided with permanently attached identification tags indicating the valves' function and what is being controlled. Post indicator valve handles shall be secured to the post indicator valve.
- c. Fire Department Connections - As defined in the Ohio Fire Code and the Ohio Building Code, the fire department connections shall be compatible with the connections of the AHJ. All threads provided for the fire department connections to the sprinkler system(s) or any other fire system supplying shall be a 5" Stortz connection with a 30-degree angle towards the ground. It shall also be 36" off of the finish grade. - All fire department connections for the sprinkler system and standpipe systems shall be installed in a location approved by the Licking Township Fire Company and be within 40' of the nearest approved fire hydrant. The fire department connection shall be marked with a red aluminum sign, 18" in height and 24" in width be mounted near fire department connection with the final location to be approved by the Licking Township Fire Company. The sign shall have white letters reading "FDC" that are 6" in height and 1" stroke: The fire department connection shall also have signage attached to the FDC, of Red aluminum that shall have 1" white letters containing the building address and what the required pump pressure shall be for the suppression system. - The water line shall be a minimum of 6" diameter line from the 5" Stortz fitting to the sprinkler riser. The fire department connection line may be a 4" line if the sprinkler water line into the building is a 4" or smaller line. - If the fire department connection is in an area subject to vehicular, impact bollards shall be installed to protect the connection following the OFC 312 guidelines. - Private fire service mains and their appurtenances shall be installed, flushed, and tested per NFPA 24. - The Licking Township Fire Companies' Fire Code Official shall inspect all underground fire line material prior to it being installed in the ground. Fire Code Official shall be notified to do a final inspection of fire hydrant locations and FDC, once all fire line material has been installed and complete. - The FDC pit shall have a solid concrete bottom and drain to a storm drain or install a sump pump.
- d. Zone maps shall be posted near the riser(s) at a location determined by the Fire Code Official.
- e. The sprinkler riser shall be placarded and have permanently attached to it the demand and design criteria.
- f. All fire department connections shall be painted "Fire Protection Red".
- g. The Licking Township Fire Company requires standpipes in buildings that exceed 150,000 square feet in size. The Fire Code Official will have discretion on standpipe locations.



# LICKING TOWNSHIP

## *Fire Company*

- h. All standpipes shall be painted fire protection red and signs posted stating "STAND PIPE".

### **L. Fire Alarm**

- a. The Licking Township Fire Company shall approve the location(s) of all fire alarm panels and remote indicators. An identification map approved by the Fire Code Official shall be installed at the alarm panel indicating fire alarm devices such as smoke detectors, pull stations, sprinkler systems, duct smoke detectors and like items. Remote annunciators shall be required in all fire pump rooms, riser rooms, inside at least one (1) main entrance to the building and inside designated fire department entry doors as determined by the Fire Code Official.
- b. Per NFPA 72, the installing contractor shall complete and sign all appropriate fire alarm completion records.
- c. Duct detector locations shall be designated by a 1" wide red plastic sign with .75" white lettering permanently attached to the ceiling grid below the unit or in a location as approved by the fire code official and shall read Duct Detector # \_\_\_\_.
- d. The Fire Company requires horn strobes to be installed on the outside wall leading into sprinkler riser/fire pump room.

### **M. Alternative Energy and Energy Storage**

- a. IFC Chapter 12 and NFPA 855 shall govern any energy generation or energy storage in, on and adjacent to any structure.

**THE ABOVE RULES AND REGULATIONS ARE IN ADDITION TO ALL FEDERAL, STATE, COUNTY, LOCAL  
AN NATIONAL CODES AND STANDARDS**